

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,
hereby attests that the product(s):

FACTORY-MADE RIGID POLYURETHANE FOAM
(Details as per the attached Scope of Certification)

manufactured by:

TIGER PROFILES & INSULATION LLC

Industrial City of Abu Dhabi 2, Mussafah , Abu Dhabi, UAE

have been assessed in accordance with DCLD Document Ref. No. RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 13165:2008

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark to the above-mentioned product(s).

ENGR. HAWWA ABDULLAH BASTAKI
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL10020138
Valid Until: 18 July 2011

Current Issue Date: 19 July 2010
Original Issue Date: 19 July 2010

This certificate is subject to the Terms and Conditions of the Product Certification System



CB-003

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL10020138**

Certificate Issued To:	TIGER PROFILES AND INSULATION LLC Industrial City of Abu Dhabi 2, Mussafah, Abu Dhabi, UAE
Applicable Standard Specification:	BS EN 13165:2008 –Thermal insulation products for buildings – Factory made rigid polyurethane foam (PUR) products - Specification
Applicable Specific Rules:	RD-DP21-2124 (IC) "Specific Rules for Certification of Factory Made Rigid Polyurethane Foam (PUR) Thermal Insulation Products (as per BS EN 13165:2008) Through Factory Assessment".

S/N	Product Description	Brand Name	Product Details
1	Factory made rigid polyurethane (PUR) foam	TIGER	PUR Insulation Foam Nominal Thickness (min) – 50 mm for wall and roof; Length (max) – 16 meters; Width (max) – 1150 mm Apparent Density 38 kg/m ³ (min); Thermal conductivity - 0.029 W/(m*K) @ 35C; Code: PUR-EN 13165-T2-DS(TH)8-CS(10/Y)100 Manufactured with either aluminum foil facing or flat or corrugated metal sheet on both or either sides to be used as thermal insulation sandwich panel.

NOTE 1: Maximum k-value measured at 35 °C temperature and 60% relative humidity condition

NOTE 2: This certification covers only the PUR foam within the panel


NOTE 3: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 4: Fire classification of the above certified product as per EN 13501-1:2007 is Class E

Date of Original Issued : 19 July 2010

Date of Current Issued : 19 July 2010

Valid Until : 18 July 2011


ENGR. AMIN AHMED MOHAMMED AMIN
Head of Inspection and Certification Section
Dubai Central Laboratory Department